



Product Service

Attestation of Conformity

No. N8A 119530 0002 Rev. 00

Holder of Attestation: **KKT KOLBE Küchentechnik GmbH & Co. KG**
Ohmstraße 17
96175 Pettstadt
GERMANY

Product: **Converter
(Hybrid Solar Inverter)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290223151901

Date, 2023-02-03

(Billy Qiu)

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

**TUV®**



Product Service

Attestation of Conformity

No. N8A 119530 0002 Rev. 00

Model(s): **HKW6-1P3, HKW8-1P3, HKW10-1P3, HKW12-1P3, HKW15-1P3**

Parameters:

Model	HKW6-1P3	HKW8-1P3	HKW10-1P3	HKW12-1P3	HKW15-1P3
Battery terminal parameters					
Rated battery DC voltage	200 Vd.c.	250 Vd.c.	300 Vd.c.	350 Vd.c.	400 Vd.c.
Battery DC voltage range	125-600 Vd.c.				
Max charging / discharging current	50 Ad.c.				
Battery type	Lithium-ion				
Maximum charge/discharge power	15000 W				
PV terminal parameters					
Max. Input Power	9000 W	12000 W	15000 W	18000 W	22500 W
Maximum DC input voltage	1000 Vd.c.				
MPPT Range	180~850 Vd.c.				
MPPT Range (full load)	250~850 Vd.c.	330~850 Vd.c.	430~850 Vd.c.	510~850 Vd.c.	620~850 Vd.c.
Max. Input Current	2*13 Ad.c.				
Isc PV	2*16 Ad.c.				2*25 Ad.c.
Grid terminal parameters					
Rated output Power	6000 W	8000 W	10000 W	12000 W	15000 W
Maximum continuous output apparent power	6600 VA	8800 VA	11000 VA	13200 VA	16500 VA
Max. AC output current	9.5 Aa.c.	12.7 Aa.c.	15.9 Aa.c.	19.1 Aa.c.	23.8 Aa.c.
Maximum continuous input apparent power	13200 VA	17600 VA	22000 VA	26400 VA	33000 VA
Max. AC input current	19 Aa.c.	25.5 Aa.c.	31.9 Aa.c.	38.2 Aa.c.	47.6 Aa.c.
Rated AC voltage	230/400 Va.c., 3W+N+PE				
Rated AC frequency	50/60 Hz				
Power factor	0.9 lagging to 0.9 leading				
Backup terminal parameters					
Rated apparent power	6000 VA	8000 VA	10000 VA	12000 VA	15000 VA
Maximum continuous output apparent power	6600 VA	8800 VA	11000 VA	13200 VA	16500 VA
Max. AC current	9.5 Aa.c.	12.7 Aa.c.	15.9 Aa.c.	19.1 Aa.c.	23.8 Aa.c.
Rated AC voltage	230/400 Va.c., 3W+N+PE				
Rated AC frequency	50/60 Hz				
General					
Protection class	I				
Ingress protection	IP 65				
Overvoltage Category	II(PV/Battery), III(Mains)				
Temperature	-25 °C ~ +60 °C, derating above 45 °C				
Altitude	≤2000				

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

Attestation of Conformity

No. N8A 119530 0002 Rev. 00

**Tested
according to:**

EN 62109-1:2010
EN 62109-2:2011

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®