

EMC Evaluation Report

Applicant: KKT KOLBE Küchentechnik GmbH & Co. KG

Address: Ohmstraße 17 96175 Pettstadt GERMANY

Product: Converter (Hybrid Solar Inverter)

Model: HKW6-1P3, HKW8-1P3, HKW10-1P3,
HKW12-1P3, HKW15-1P3






China

Add value.
Inspire trust.

COMMERCIAL-IN-CONFIDENCE

Report Number: 64.772.21.30684.01M

RESPONSIBLE FOR	NAME	SIGNATURE	DATE
Prepared by	Charlie Wu		2023-01-03
Approved by	Samuel Zhang	 	2023-01-03

Signatures in this approval box have checked this document in line with the requirements of TÜV SÜD Product Service control rules.

EXECUTIVE SUMMARY This product was tested and found to be in compliance with	EN IEC 61000-6-1:2019 EN IEC 61000-6-2:2019 EN IEC 61000-6-3:2021 EN IEC 61000-6-4:2019 EN IEC 61000-3-2:2019/A1:2021 EN 61000-3-3:2013/A2:2021 EN IEC 61000-3-11:2019 EN 61000-3-12:2011
--	--

TÜV SÜD Certification and Testing
(China) Co., Ltd. Guangzhou Branch

5/F & East of 8/F., Communication
Building, No.163, Pingyun Road, West
of Huangpu Avenue, Guangzhou, China

Phone: +86 20 3815 3200
Fax: +86 20 3832 0478
www.tuvsud.com

ID Number: GCN_SR EMC_TR_001
Revision:2.0
Effective:2019-12-26





China

Contents

- 1 Report Summary3**
- 1.1 Report Modification Record.....3
- 1.2 Introduction.....3
- 1.3 General Remarks3

1 Report Summary

1.1 Report Modification Record

Alterations and additions to this report will be issued to the holders of each copy in the form of a complete document.

Issue	Description of Change	Date of Issue
1	First Issue	2023-01-03

1.2 Introduction

The information contained in this report is intended to show verification of the EMC Qualification

Applicant : KKT KOLBE Küchentechnik GmbH & Co. KG
 Address : Ohmstraße 17 96175 Pettstadt GERMANY
 Manufacturer : Same as the applicant
 Address : Same as the applicant
 Model Number(s) : HKW6-1P3, HKW8-1P3, HKW10-1P3, HKW12-1P3, HKW15-1P3
 Product Type : Converter (Hybrid Solar Inverter)
 Trademark : /

1.3 General Remarks

Please refer to report 64.772.21.30684.01 for all test data.

Change the applicant and model number in this report. By evaluation, no test is needed to perform.

Co-license Model	is technically identical to	Main Certificate Model
HKW6-1P3	is technically identical to	R6KH3
HKW8-1P3	is technically identical to	R8KH3
HKW10-1P3	is technically identical to	R10KH3
HKW12-1P3	is technically identical to	R12KH3
HKW15-1P3	is technically identical to	R15KH3